

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTINGS No. 3330-1535:100 Page 1 of 1

CATEGORY: Access Door (Fire-Rated)

LISTEE: MIFAB Manufacturing Inc., 101 Canola Ave., North Battleford, SK Canada S9A 2Y3
Contact: Jim Whiteside (306) 445-7201 Fax (306) 446-2499

DESIGN: Models MPFR and MFRU side hinge, fire rated access doors. Constructed of 16 Ga. or 20 Ga. MSG cold-rolled steel or stainless steel (Type 302 or 304) faces and may be filled with mineral wool insulation. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 1-1/2 Hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL Label.

APPROVAL: Listed as 1-1/2 Hr. fire-rated access door for use where access openings are permitted to provide fire protection to access openings in vertical shafts or utility spaces. Intended to be installed in masonry type firewalls. Insulated doors that have dimension exceeding 30" in width and 36" in height shall be provided with two latches equally spaced. Maximum size of any doors shall not to exceed 36" in width and 48" in height.

10-12-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager